



integrated solutions

Certificate of Compliance

Type Approval

Issued to: Kungsörs Plast AB, Fabriksgatan 3, Box 70, S-73622 Kungsör, Sweden

Product range: KPS Petrol Pipe System™

This certificate covers only those items listed on the attached pages, and should only be reviewed or reproduced in full.

Applications: Positive pressure and vacuum suction delivery, vent lines, fill pipes, vapour recovery and secondary containment Type SC2.

This is to certify that samples of the items listed on the attached pages have been tested by ERA Technology Ltd and have been found to comply with the requirements of the following standard for initial type testing:

EN14125:2004 Thermoplastic and flexible metal pipework for underground installation at petrol filling stations

Full details are given in ERA report number : 2005-0584 Issue 4

NOTE 1: Compliance with the requirement for permeability is based on tests of 6 months' duration, supported by additional evidence including tests of 2 years' duration. Approval is subject to the permeability remaining within the specified limits.

NOTE 2: This certificate supersedes Certificate BC66/2005-0584/002

NOTE 3: This certificate remains the property of ERA Technology Ltd. ERA reserves the right to withdraw or revise it following written notification to the issuee. Any revision is indicated by a change in certificate number.

Conditions on the validity of this Certificate: None

Certificate prepared by :

J H Greenwood
Non-Metals Consultant

Certificate approved by :

S T Brown
Head of Engineering Consultancy
Services

Certificate number : BC66/2005-0584/003 Dated : 9 March 2006

ERA Technology Ltd, Cleeve Road, Leatherhead, Surrey KT22 7SA, UK